

WQBEL BIOLOGIST RECOMMENDATIONS
Ludington Waste Water Treatment Plant WWTP - (MI0021334- REISSUANCE)
PREPARED BY: Darrin McCullough
11/10/2020

Background

The City of Ludington submitted a National Pollutant Discharge Elimination System (NPDES) permit application in September 2020 for reissuance of the Ludington WWTP located in Ludington, Michigan, Mason County. The current NPDES permit was issued on September 24, 2015, took effect on October 1, 2015, and expired on October 1, 2020 but has been extended. The current NPDES permit authorizes to discharge treated municipal wastewater from Monitoring Point 001A through Outfall 001 to an unnamed oxbow wetland tributary to the Pere Marquette River at a design flow of 4.5 million gallons per day (MGD) (but this flow is not to be considered a limitation or actual capacity). The current NPDES permit also authorizes to discharge treated municipal wastewater from Monitoring Point 002A through Outfall 002. Outfall 002 discharges to the Pere Marquette River North Branch at a design flow of 4.5 million gallons per day (MGD) but is not to be considered a limitation or actual capacity. Outfall 002 is a new outfall location that began discharge in July 2018, replacing Outfall 001. Outfall 001 previously discharged to a no stream flow oxbow of the Pere Marquette River North Branch. The Pere Marquette River North Branch has a 95 percent exceedance, harmonic mean, and 90dQ10 low flows of 260, 460, and 290 cubic feet per second (cfs), respectively [EGLE Low Flow Database File No. 9518].

The Pere Marquette River North Branch near the Ludington WWTP is not designated as public drinking water supply source. The Pere Marquette River North Branch, which flows into Pere Marquette Lake, is a designated coldwater trout stream.

A receiving water body hardness of 150 milligrams per liter (mg/l) was used for this review and was collected upstream of Outfall 001 during a September 2009 Compliance Sampling Inspection (CSI). This hardness value is consistent with additional hardness samples collected in upstream locations of the Pere Marquette watershed as part of the Water Contaminant Monitoring Program (WCMP).

The 2020 Water Quality and Pollution Control in Michigan Sections 303(d), 305(b), and 314 Integrated Report indicates the Pere Marquette River North Branch (Assessment Unit ID (AUID) 040601010509-06) is Fully Supporting Water Quality Standards (WQS) for the Navigation, Industrial Water Supply, and Agriculture designated uses. The Pere Marquette River North Branch is Not Supporting the Fish Consumption designated use due to polychlorinated biphenyls (PCBs) in the fish tissue water column. All other designated uses are listed as not assessed or insufficient information. A Total Maximum Daily Load (TMDL) for PCBs was developed in 2008.

A search of available information for endangered, threatened, or sensitive species for the Pere Marquette River North Branch near Outfall 002 and downstream Pere Marquette Lake found the following aquatic species identified as endangered, threatened, or sensitive species:

| Common Name | Scientific Name | Status | Date Last Observed |
|--------------------|-------------------------------|-----------------|---------------------------|
| Paper pondshell | <i>Utterbackia imbecillis</i> | Special Concern | Historical |
| Pickerel frog | <i>Lithobates palustris</i> | Special Concern | Historical |

Sources

Sources of information used for this review to develop the WQBELs include the facility's NPDES permit reissuance application, the current NPDES permit, the Permits Section Toxics facility file, discharge monitoring report data from October 2015 through November 2020, a September 2009 Compliance Sampling Inspection, and United States Geological Survey topographical maps. Based upon our review of this information, we have the following recommendations:

Recommendations

- 1) We recommend the conditions in the current NPDES permit in Part I.A.1 for Monitoring Point 001A, Outfall 001 to be removed from the draft NPDES permit as the facility no longer discharges through Outfall 001.
- 2) The current NPDES permit includes a daily monitoring requirement for final effluent flow for Outfall 002. Final effluent flow ranged from 0.0 MGD to 5.9 MGD, averaging 2.3 MGD. Final effluent flow exceeded the 4.5 MGD design flow on 26 days during the period of this review. **Based on this information, we recommend the current daily monitoring and reporting requirement of final effluent flow be retained in the draft permit.**
- 3) The current NPDES permit includes daily minimum and maximum pH limits of 6.5 to 9.0 Standard Units (S.U.) measured daily as grab samples. Levels of pH in the Outfall 002 final effluent ranged from 5.9 to 7.7 S.U., averaging 6.7 S.U. The daily minimum pH limit was exceeded on 3 days during the period of this review. **Based on this information, we recommend the current daily monitoring requirements be retained in the draft permit with daily minimum and maximum pH limits of 6.5 to 9.0 S.U.**
- 4) The current NPDES permit includes a daily maximum final effluent concentration limit for total residual chlorine of 0.038 mg/l with compliance monitoring collected as daily grab samples. Total residual chlorine concentrations in the Outfall 002 final effluent ranged from non-detect [QL < 0.01 milligrams per liter (mg/l)] to 0.03 mg/l. Based on this information, we recommend the current daily monitoring requirements as well as the daily maximum final effluent limit of 0.038 mg/l for total residual chlorine be retained in the draft permit. However, we recommend the final effluent limit be changed to 38 micrograms per liter (ug/l).
- 5) The current NPDES permit includes a daily maximum final effluent concentration limit for total copper of 61 ug/l, a monthly average concentration limit of 20 ug/l, a daily maximum loading limit of 2.3 pounds per day (lbs/day), and a monthly average loading limit of 0.8 lbs/day with compliance monitoring collected as monthly 24-hour composite samples. Concentrations of total copper ranged from 4.8 ug/l to 48 ug/l, averaging 12 ug/l. Based on this information, there is not a reasonable potential for total copper to be discharged in exceedance of Michigan WQS. **We recommend the current limits and monitoring requirements for total copper be removed from the draft permit but included in the Additional Monitoring Requirements in the draft permit.**
 - a. It appears the current permit limits and loading requirements for total copper are based on the discharge from Outfall 001 to the no stream flow oxbow of the Pere Marquette River North Branch. As Outfall 001 has been decommissioned and Outfall 002 discharges directly to the Pere Marquette River North Branch, there is not a reasonable potential for total copper to be discharged in exceedance of Michigan WQS.
- 6) The current NPDES permit includes a Whole Effluent Toxicity (WET) daily maximum limit of 1.0 acute toxicity units (TUa) and a monthly average limit of 6.6 chronic toxicity units (TUc) for *Ceriodaphnia dubia* (*C. dubia*) and fathead minnow with monthly compliance monitoring on both organisms. Acute toxicity for all testing events for *Ceriodaphnia dubia* (*C. dubia*) were reported as 0.0 TUa. Chronic toxicity for *C. dubia* ranged from 0.0 TUc to 1.7 TUc. Acute toxicity for all testing events for fathead minnow were reported as 0.0 TUa. Chronic toxicity for fathead minnow ranged from 0.0 TUc to 1.7 TUc. Based on this information, there is not a reasonable potential for the Outfall 002 final effluent to be acutely and/or chronically toxic to aquatic organisms. **We recommend the draft NPDES permit remove the current permit limits and monitoring requirements for fathead minnow and include WET testing requirements in the Additional Monitoring Requirements with testing conducted on fathead minnow for a total of four tests. Additionally, based on persistent low level chronic toxicity to *C. dubia*, we recommend the draft NPDES permit include a quarterly compliance monitoring requirement for *C. dubia*.**
 - a. Testing and reporting requirements shall follow procedures contained in EPA-821-R-02-013, "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to

Freshwater Organisms (Fourth Edition). Samples for WET shall be collected as 24-hour composite samples.

- b. The current permits chronic toxicity limit of 6.6 TUc was based on a design flow of 7.5 MGD.
- c. The allowable level of chronic toxicity, based on the requested 4.5 MGD design flow, would be 10.3 TUc.
- d. We do not recommend monitoring frequency reduction language be included in the draft permit to develop an adequate dataset for the next permit cycle.

7) The current NPDES permit includes a monthly average total phosphorus concentration limit of 1.0 mg/l with 5X weekly compliance monitoring as a 24-hour composite sample. In addition, the current permit includes a monthly average loading limit of 29 lbs/day. Outfall 002 is located immediately upstream of Pere Marquette Lake. Concentrations of total phosphorus in the Outfall 002 final effluent ranged from 0.2 to 2.2 mg/l, averaging 0.75 mg/l. Loading of total phosphorus ranged from 3.0 to 65 lbs/day, averaging 13 lbs/day. The monthly average concentration limit and the monthly average loading limit were never exceeded during the period of this review. **Based on this information and to protect the Pere Marquette River and Pere Marquette Lake from excessive nutrients, we recommend the current 5X weekly monitoring requirements for total phosphorus as well as the current monthly average concentration limit of 1.0 mg/l and the monthly average loading limit of 29 lbs/day be retained in the draft permit.**

- a. The current loading limit of 29 lbs/day has been in the facility's NPDES permit for multiple permit cycles.
- b. We recommend retaining the current loading limit of 29 lbs/day as the facility has regularly met this loading limit and to also ensure continued protection of Pere Marquette Lake from nutrient enrichment.
- c. We do not recommend monitoring frequency reduction language be included in the draft permit to develop an adequate dataset for the next permit cycle.

8) The current NPDES permit includes a Level Currently Achievable (LCA) 12-Month rolling average concentration limit of 3.0 nanograms per liter (ng/l) for total mercury and a 12-Month rolling average loading limit of 0.00011 lbs/day with compliance samples collected as quarterly grab samples. Part I.A.4. of the current NPDES permit also describes the requirements for the Pollutant Minimization Program (PMP) for total mercury. Concentrations of total mercury in the Outfall 001 and Outfall 002 final effluent from August 2015 to July 2020 ranged from non-detect (QL <0.5 ng/l) to 3.2 ng/l. The 12-month rolling average concentration of total mercury as of July 2020 is 1.3 ng/l, which includes a non-detect of <0.5 ng/l. The non-detect value was entered as 0.5 ng/l to determine the current 12-month rolling average. Based on the final effluent data for total mercury, there is a reasonable potential for total mercury to be discharged from Outfall 002 at levels exceeding Michigan WQS. **Based on this information, we recommend the draft permit include a LCA 12-Month rolling average concentration limit of 2.0 ng/l for total mercury and a 12-Month rolling average loading limit of 0.00007 lbs/day.** Monitoring for total mercury shall be quarterly with samples collected as grab samples using USEPA method 1669 and analyzed using USEPA method 1631 with a quantification level of 0.5 ng/l. In addition, we recommend the PMP requirements be retained in the draft permit.

- a. Review of total mercury final effluent data and reasonable potential analysis was consistent with Water Resources Division, Policy and Procedure, WRD-004, Calculation of Level Currently Achievable (LCA) for Mercury in Proposed National Pollutant Discharge Elimination System (NPDES) Permits.
- b. The "n" value in the PEL Sheet was put at 4 instead of 30.

- c. Quarterly monitoring is recommended as the facility has consistently demonstrated low concentrations of total mercury and compliance with the current LCA.
 - d. We do not recommend monitoring frequency reduction language be included in the draft permit to develop an adequate dataset for the next permit cycle.
 - e. The current loading limit of 0.00011 lbs/day is based on the current design flow of 4.5 MGD.
 - f. The loading limit of 0.00007 lbs/day is based on the current design flow of 4.5 MGD and an LCA of 2.0 ng/l.
- 9) The current NPDES permit does not include a monitoring requirement for Perfluorooctanoic Acid (PFOA). However, effluent samples have been collected as part of the ongoing IPP initiative to identify and reduce sources of PFAS from municipal WWTPs. Concentrations of PFOA were reported to range from non-detect (QLs ranged from <6.1 ng/l to <8.0 ng/l) to 8.88 ng/l. Based on the available data, there is not a reasonable potential for PFOA to be discharged at concentrations exceeding Michigan WQS. Based on this information, we have no recommendations for PFOA.
- a. The theoretical WQBEL for PFOA is 210 ug/l (7.9 lbs/day) as a Monthly Average WQBEL and 15,000 ug/l (560 lbs/day) as a Daily Maximum WQBEL.
- 10) The current NPDES permit does not include a monitoring requirement for Perfluorooctane Sulfonate (PFOS). However, effluent samples have been collected as part of the ongoing IPP initiative to identify and reduce sources of PFAS from municipal WWTPs. Ludington WWTP was required to sample for PFOS biannually since October of 2018. Levels of PFOS in the final effluent ranged from non-detect (QLs ranged from <6.1 ng/l to <8.0 ng/l) to 6.6 ng/l. Based on this information, there is a reasonable potential for PFOS to be discharged at levels exceeding Michigan WQS.
- a. Based on the available data, the facility would fall into Bin 2 of the Municipal NPDES Permitting Strategy for PFOS and PFOA. As such, we recommend a twice annual monitoring requirement with appropriate trigger language consistent with the Municipal NPDES Permitting Strategy for PFOS and PFOA.
 - b. After the submittal of 60 months of monthly data or at least 10 equally spaced data points over a minimum of 3 months, the permittee may request, in writing, Department approval of a reduction in monitoring frequency for PFOS. This request shall contain an explanation as to why the reduced monitoring is appropriate.

The recommendations contained herein are based on the Part 4 Water Quality Standards and Part 8 Water-Quality Based Effluent Limit Development for Toxic Substances. Treatment methods or economic concerns have not been addressed. We understand that other considerations may be used in deciding permit limits and requirements.

All other data reviewed indicated there was not a reasonable potential for these parameters to be discharged at concentrations exceeding Michigan WQS. These data were either provided with the NPDES permit application or in the facility's Daily Monitoring Report (DMR) data. Parameters with results reported as all Not Detected were also reviewed. Based on this information, we have no recommendations for these parameters. Refer to the PEL sheet and permit application for a list of other parameters reviewed.

NPDES PERMIT REVIEW SUMMARY

| | |
|-----------------------|-------------------|
| Facility: | Ludington WWTP |
| Permit Number: | MI0021334 |
| Reviewer: | Darrin McCullough |
| Date: | 11/10/2020 |

| Outf. | Authorized Flow | | Disch. Type * | Receiving Water | Lake? | FLOWS (cfs) | | | pH | Hardness |
|-------|-----------------|------|---------------|----------------------|--------------------------|-------------|---------|-------|----|----------|
| | mgd | cfs | | | | 95% Exc. | H. Mean | 90Q10 | | |
| 002 | 4.5 | 6.97 | s | Pere Marquette River | <input type="checkbox"/> | 260.0 | 460.0 | 290.0 | 7 | 150 |

* P = Process; N = Noncontact Cooling; C = Contact Cooling; S = Sanitary; ST = Storm Water; GW = Groundwater Purge

SOURCES REVIEWED

TYPE OF REVIEW: (NPDES Permit Reissuance)

LOW FLOW FILE NO.: 9518

HARDNESS SOURCE: 2009 Compliance Sampling Inspection. Hardness samples not collected upstream during 2019 CSI.

PEL SHEET VERSION: 2/1/2020

Review the Following Information Sources

- Permit Application**
- Facility/VGW File**
- MiWaters Documents & Files**
- Current Permit**
- WTA's**
- Staff Report #'s**
- WET Tests**
- Other**

REASONABLE POTENTIAL: CHEMICAL SPECIFIC (p. 1 of 2)

*concentration values in ug/L except as noted

| | | | |
|-----------|----------------|-----------------|----------------|
| Facility: | Ludington WWTP | Hardness: | 150 mg/L CaCO3 |
| Outfall: | 2 | pH: | 7 |
| Date: | 11/10/2020 | Drinking Water: | n |

| Parameter | CAS # | Water Quality Values | | | | | | | | | | Diss. Met. Translator | Background Conc. |
|-----------------------------|---------|----------------------|---------|--------|---------|------|---------|--------|---------|-------------|---------|-----------------------|------------------|
| | | FCV | vd | HNW | vd | HCV | vd | WV | vd | FAV | vd | | |
| Mercury @ | 7439976 | 0.77 | 1199707 | 0.0018 | 1199707 | NA | 0 | 0.0013 | 1199707 | 2.8 | 1199707 | 1 | ** |
| Copper | 7440508 | 12.66403219 | 1199707 | 38000 | 1200512 | NA | 0 | NA | 0 | 39.38345326 | 1199707 | 1.5 | 4 |
| Perfluorooctane sulfonate @ | 1763231 | 140 | 2201408 | 0.012 | 1201403 | NA | 0 | NA | 0 | 1600 | 2201408 | 1 | 0 |
| Perfluorooctanoic acid | 335671 | 880 | 2201007 | 12 | 1201105 | NA | 0 | NA | 0 | 15000 | 2201007 | 1 | 0 |
| Boron | 7440428 | 7200 | 1201511 | 330000 | 1201511 | NA | 0 | NA | 0 | 69000 | 1201511 | 1 | 0 |
| Barium | 7440393 | 677.631923 | 2201912 | 470000 | 1202001 | NA | 0 | NA | 0 | 3842.599056 | 2201912 | 1 | 0 |
| Nickel | 7440020 | 73.28771162 | 1199707 | 210000 | 1199706 | NA | 0 | NA | 0 | 1319.677459 | 1199707 | 1.1 | 3 |
| Selenium | 7782492 | 5 | 1199707 | 2700 | 1199704 | NA | 0 | NA | 0 | 120 | 1199808 | 1 | 0 |
| Zinc | 7440666 | 166.5694535 | 1199707 | 16000 | 1200510 | NA | 0 | NA | 0 | 330.4359543 | 1199707 | 2.1 | 13 |
| Acrylonitrile # | 107131 | 66 | 2201010 | 320 | 1200708 | 1.2 | 1200708 | NA | 0 | 1200 | 2201010 | 1 | 0 |
| Chloroform # | 67663 | 630 | 2201501 | 11000 | 1201509 | * | 201509 | NA | 0 | 11000 | 1201509 | 1 | 0 |
| Azobenzene # | 103333 | 4.1 | 3201004 | ID* | 201004 | 6 | 2201004 | NA | 0 | 74 | 3201004 | 1 | 0 |
| Pentachlorophenol # | 87865 | 6.692583681 | 1199707 | 450 | 1199710 | 2.8 | 1199710 | NA | 0 | 17.44664176 | 1199707 | 1 | 0 |
| Phenanthrene | 85018 | 1.7 | 2201411 | ID* | 199706 | NA | 0 | NA | 0 | 11 | 2201411 | 1 | 0 |
| Cyanide, free | 57125 | 5.2 | 1199707 | 48000 | 1199707 | NA | 0 | NA | 0 | 44 | 1199707 | 1 | 0 |
| Fluoranthene | 206440 | 1.6 | 2201411 | 18 | 2199901 | NA | 0 | NA | 0 | 28 | 1201411 | 1 | 0 |
| #N/A | 1 | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A |
| #N/A | 0 | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A |
| #N/A | 0 | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A |
| #N/A | 0 | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A |

= Carcinogen

** = Background exceeds standards.

REASONABLE POTENTIAL: CHEMICAL SPECIFIC (p. 2 of 2)

*concentration values in ug/L except as noted; loads in lb/d

| | | | | | | | |
|-----------|----------------|--------------|----------|---------------|---------|--|----------------|
| Facility: | Ludington WWTP | Disch. Rate: | 6.97 cfs | 95% Ex. Flow: | 260 cfs | Conc. | Load (lbs/day) |
| Outfall: | 002 | | | H. Mean Flow: | 460 cfs | Hg Loading Calculated based on LCA (ng/L) of : | 2 0.00007506 |
| Date: | 11/10/2020 | | | 90Q10 Flow: | 290 cfs | TP Loading based on concentration (mg/L) of : | 1 37.53 |

| Parameter | Monthly Average PEL | | | | | | | | Daily Max PEL | | PEQ | | DECISION | |
|-----------------------------|---------------------|----------|------------|----------|----------|----------|---------|------------|---------------|----------|----------|----------|----------|---|
| | FCV | load | HNV | load | HCV | load | WV | load | conc | load | Avg | Max | Avg | Max |
| Mercury @ | 0.77 | 0.028898 | 0.0018 | 6.76E-05 | NA | #VALUE! | 0.0013 | 4.8789E-05 | 2.8 | 0.105084 | 0.00165 | 0.002325 | PEQ>10 | Reasonable Potential. Recommend LCA of 2.0 ng/l(0.000075 lbs/day). Quarterly monitoring. |
| Copper | 158.925841 | 5.964487 | 665271.742 | 24967.65 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 59.07518 | 2.217092 | 14.17571 | 24.8991 | PEQ>10 | No Reasonable Potential. Recommend removing limit and monitoring requireemnt from draft permit limits page. Include copper in Additional Monitoring requirements. |
| Perfluorooctane sulfonate @ | 140 | 5.2542 | 0.012 | 0.00045 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 1600 | 60.048 | 0.017082 | 0.017082 | PEQ>10 | Reasonable Potential. Bin 2 according to Municipal PFAS Strategy. 2X annual monitoring with trigger language. |
| Perfluorooctanoic acid | 9091.377778 | 341.1994 | 210.106667 | 7.885303 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 15000 | 562.95 | 0.023088 | 0.023088 | | No Reasonable Potential. No recommendations. |
| Boron | 74384 | 2791.632 | 5777933.33 | 216845.8 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 69000 | 2589.57 | 546 | 546 | | No Reasonable Potential. No recommendations. |
| Barium | 7000.690689 | 262.7359 | 8229177.78 | 308841 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 3842.599 | 144.2127 | 54.6 | 54.6 | | No Reasonable Potential. No recommendations. |
| Nickel | 804.8645076 | 30.20656 | 3676817.14 | 137990.9 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 1451.645 | 54.48024 | 18.2 | 18.2 | | No Reasonable Potential. No recommendations. |
| Selenium | 51.65555556 | 1.938633 | 47274 | 1774.193 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 120 | 4.5036 | 6.76 | 6.76 | | No Reasonable Potential. No recommendations. |
| Zinc | 3492.475371 | 131.0726 | 279927.607 | 10505.68 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 693.9155 | 26.04265 | 41.6 | 41.6 | | No Reasonable Potential. No recommendations. |
| Acrylonitrile # | 681.8533333 | 25.58996 | 5602.84444 | 210.2748 | 21.01067 | 0.78853 | #VALUE! | #VALUE! | 1200 | 45.036 | 0 | 0 | | No Reasonable Potential. Sufficiently sensitive QL. No recommendations. |
| Chloroform # | 6508.6 | 244.2678 | 192597.778 | 7228.195 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 11000 | 412.83 | 4.94 | 4.94 | | No Reasonable Potential. No recommendations. |
| Azobenzene # | 42.35755556 | 1.589679 | #VALUE! | #VALUE! | 105.0533 | 3.942652 | #VALUE! | #VALUE! | 74 | 2.77722 | 0 | 0 | | No Reasonable Potential. Sufficiently sensitive QL. No recommendations. |
| Pentachlorophenol # | 69.14182563 | 2.594893 | 7879 | 295.6989 | 49.02489 | 1.839904 | #VALUE! | #VALUE! | 17.44664 | 0.654772 | 0 | 0 | | No Reasonable Potential. Sufficiently sensitive QL. No recommendations. |
| Phenanthrene | 17.56288889 | 0.659135 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 11 | 0.41283 | 0 | 0 | | No Reasonable Potential. Sufficiently sensitive QL. No recommendations. |
| Cyanide, free | 53.72177778 | 2.016178 | 840426.667 | 31541.21 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 44 | 1.65132 | 31.2 | 31.2 | | No Reasonable Potential. No recommendations. |
| Fluoranthene | 16.52977778 | 0.620363 | 315.16 | 11.82795 | #VALUE! | #VALUE! | #VALUE! | #VALUE! | 28 | 1.05084 | 0 | 0 | | No Reasonable Potential. Sufficiently sensitive QL. No recommendations. |
| #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | 0 | 0 | | |
| #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | 0 | 0 | | |
| #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | 0 | 0 | | |
| #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | #N/A | 0 | 0 | | |

* SILVER - Appropriate Dissolved Metal Translator must be entered in PEL 1

PEQ -- Effluent Data Summary

(all values in ng/l.)

DATA ENTRY

| Parameter: | Mercury @ | Source | Copper | Source | Perfluorooctane sulfonate @ | Source | Perfluorooctanoic acid | Source | Boron | Source |
|---------------|---------------|------------|----------|------------|-----------------------------|------------|---------------------------|------------|----------|------------|
| No. Nondetect | 3 | | 0 | | 2 | | 2 | | 0 | |
| Data | 0.0018 | 7/16/2020 | 48 | 9/14/2020 | 0.00657 | 6/21/2019 | 0.00888 | 6/21/2019 | 170 | 8/26/2019 |
| | 0.0011 | 1/16/2020 | 17 | 7/16/2020 | 0.00492 | 10/29/2018 | 0.00482 | 10/29/2018 | 180 | 3/20/2018 |
| | 0.0019 | 7/17/2019 | 16 | 6/22/2020 | | | | | 160 | 5/16/2017 |
| | 0.0018 | 1/22/2019 | 28 | 5/27/2020 | | | | | 210 | 10/14/2016 |
| | 0.00057 | 10/10/2018 | 27 | 4/20/2020 | | | | | | |
| | 0.00097 | 7/17/2018 | 19 | 3/9/2020 | | | | | | |
| | 0.00071 | 4/12/2018 | 13 | 1/16/2020 | | | | | | |
| | 0.0009 | 1/23/2018 | 11 | 12/18/2019 | | | | | | |
| | 0.00054 | 7/17/2017 | 21 | 11/25/2019 | Non-Detect | | Non-Detect | | | |
| | 0.0032 | 4/10/2017 | 8.8 | 10/1/2019 | 6/3/2020 QL < 6.14 ng/l | | 6/3/2020 QL < 6.14 ng/l | | | |
| | 0.0008 | 1/12/2017 | 9.7 | 9/26/2019 | 12/19/2019 QL < 7.97 ng/l | | 12/19/2019 QL < 7.97 ng/l | | | |
| | 0.0006 | 10/13/2016 | 12 | 8/26/2019 | | | | | | |
| | 0.0005 | 7/11/2016 | 6 | 7/16/2019 | | | | | | |
| | 0.00063 | 4/12/2016 | 13 | 6/19/2019 | | | | | | |
| | 0.00073 | 1/7/2016 | 10 | 5/20/2019 | | | | | | |
| | 0.00078 | 10/5/2015 | 14 | 4/10/2019 | | | | | | |
| | 0.0012 | 8/12/2015 | 14 | 3/10/2019 | | | | | | |
| | | | 14 | 2/18/2019 | | | | | | |
| | | | 15 | 1/21/2019 | | | | | | |
| | | | 14 | 12/19/2018 | | | | | | |
| | | | 13 | 11/26/2018 | | | | | | |
| | Non-Detect | | 7.6 | 10/9/2018 | | | | | | |
| | QL < 5.0 ng/l | | 5.8 | 9/11/2018 | | | | | | |
| | 10/10/2019 | | 12 | 8/5/2018 | | | | | | |
| | 4/10/2019 | | 10 | 7/12/2018 | | | | | | |
| | 10/10/2017 | | 9.1 | 6/11/2018 | | | | | | |
| | | | 13 | 5/14/2018 | | | | | | |
| | | | 12 | 4/12/2018 | | | | | | |
| | | | 12 | 3/20/2018 | | | | | | |
| | | | 8.7 | 2/14/2018 | | | | | | |
| | | | 7.5 | 1/23/2018 | | | | | | |
| | | | 12 | 12/20/2017 | | | | | | |
| | | | 13 | 11/16/2017 | | | | | | |
| | | | 5.7 | 10/9/2017 | | | | | | |
| | | | 8 | 9/24/2017 | | | | | | |
| | | | 7.4 | 8/16/2017 | | | | | | |
| | | | 5.1 | 7/16/2017 | | | | | | |
| | | | 4.8 | 6/15/2017 | | | | | | |
| | | | 6.9 | 5/16/2017 | | | | | | |
| | | | 13 | 4/10/2017 | | | | | | |
| | | | 14 | 3/12/2017 | | | | | | |
| | | | 13 | 2/12/2017 | | | | | | |
| | | | 11 | 1/9/2017 | | | | | | |
| | | | 20 | 12/14/2016 | | | | | | |
| | | | 10 | 11/10/2016 | | | | | | |

PEQ -- Effluent Data Summary

(all values in ug/l.)

| Parameter: | Barium | Source | Nickel | Source | Selenium | Source | Zinc | Source | Acrylonitrile # | Source | Chloroform # | Source | Azobenzene # | Source |
|---------------|----------|------------|--|-----------|---|-----------|--|------------|-----------------|--|--------------|--|--------------|---|
| No. Nondetect | 0 | | 1 | | 2 | | 0 | | 4 | | 3 | | 4 | |
| Data | 12 | 8/26/2019 | 7 | 8/26/2019 | 1.4 | 8/26/2019 | 5.4 | 8/26/2019 | | | 1.9 | 8/26/2019 | | |
| | 21 | 3/20/2018 | 6.2 | 3/20/2018 | 2.6 | 3/20/2018 | 16 | 3/20/2018 | | | | | | |
| | 19 | 5/16/2017 | 5.6 | 5/16/2017 | | | 7.9 | 5/16/2017 | | | | | | |
| | 15 | 10/14/2016 | | | | | 11 | 10/14/2016 | | | | | | |
| | | | Non-Detect QL <5.0 ug/l 10/14/2016 | | Non-Detect QL <1.3 ug/l 5/16/2017 10/14/2016 | | Non-Detect QL <10 ug/l 8/26/2019 3/20/2018 5/16/2017 10/14/2016 | | | Non-Detect QL <1.0 ug/l 3/20/2018 5/16/2017 10/14/2016 | | Non-Detect QL <1.0 ug/l 3/20/2018 5/16/2017 10/14/2016 | | Non-Detect QL <5 ug/l 8/26/2019 3/20/2018 5/16/2017 10/14/2016 |

PEQ -- Effluent Data Summary
(all values in ug/L)

| Parameter: | Pentachlorophenol # | Source | Phenanthrene | Source | Cyanide, free | Source | Fluoranthene | Source | #N/A | Source | #N/A | Source | #N/A | Source |
|---------------|---------------------|--------------------------|--------------|--------------------------|---------------|----------------------------|--------------|--------------------------|------|--------|------|--------|------|--------|
| No. Nondetect | 4 | | 4 | | 1 | | 4 | | 0 | | 0 | | 0 | |
| Data | | | | | 4.4 | 8/26/2019 | | | | | | | | |
| | | | | | 4.8 | 5/16/2017 | | | | | | | | |
| | | | | | 12 | 10/14/2016 | | | | | | | | |
| | | Non-Detect QL <5 ug/l | | Non-Detect QL <5 ug/l | | Non-Detect QL <2.0 ug/l | | Non-Detect QL <5 ug/l | | | | | | |
| | | 8/26/2019 | | 8/26/2019 | | 3/20/2018 | | 8/26/2019 | | | | | | |
| | | 3/20/2018 | | 3/20/2018 | | | | 3/20/2018 | | | | | | |
| | | 5/16/2017 | | 5/16/2017 | | | | 5/16/2017 | | | | | | |
| | | 10/14/2016 | | 10/14/2016 | | | | 10/14/2016 | | | | | | |

PROJECTED EFFLUENT QUALITY ANALYSIS (<10 Detectable):

* all values in ug/l

| | Mercury @ | Copper | Perfluorooctane sulfonate @ | Perfluorooctanoic acid | Boron | Barium | Nickel | Selenium | Zinc | Acrylonitrile # | Chloroform # | Azobenzene # | Pentachlorophenol # | Phenanthrene | Cyanide, free | Fluoranthene | #N/A | #N/A | #N/A | #N/A |
|---------------|----------------|-------------|-----------------------------|------------------------|------------|-------------|-------------|-------------|-------------|-----------------|--------------|--------------|---------------------|--------------|---------------|--------------|----------|----------|----------|----------|
| Sample Max. | 0.0019 | 48 | 0.00657 | 0.00888 | 210 | 21 | 7 | 2.6 | 16 | 0 | 1.9 | 0 | 0 | 0 | 12 | 0 | 0 | 0 | 0 | 0 |
| Total Samples | 12 | 9 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 0 | 0 | 0 | 0 |
| Multiplier | 1.6 | 1.8 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 0 | 0 | 0 | 0 |
| PEQ: | 0.00304 | 86.4 | 0.017082 | 0.023088 | 546 | 54.6 | 18.2 | 6.76 | 41.6 | 0 | 4.94 | 0 | 0 | 0 | 31.2 | 0 | 0 | 0 | 0 | 0 |

PROJECTED EFFLUENT QUALITY ANALYSIS (>=10 Detectable):

| PARAMETER: | Mercury @ | | Copper | | Perfluorooctane sulfonate @ | | Perfluorooctanoic acid | | Boron | | Barium | |
|--------------------------|--------------------|----------------|----------------|-----------------|------------------------------------|--------------------|-------------------------------|-------------------|------------------|------------------|------------------|------------------|
| TOTAL NO. VALUES: | 20 | | 58 | | 4 | | 4 | | 4 | | 4 | |
| DETECTED: | 17 | | 58 | | 2 | | 2 | | 4 | | 4 | |
| NON-DETECTED: | 3 | | 0 | | 2 | | 2 | | 0 | | 0 | |
| d (% data<detect) | 0.15 | | 0 | | 0.5 | | 0.5 | | 0 | | 0 | |
| m (mean of data >detect) | 0.001101765 | | 12.03276 | | 0.005745 | | 0.00685 | | 180 | | 16.75 | |
| std dev | 0.000707268 | | 6.79539 | | 0.001167 | | 0.002871 | | 21.602469 | | 4.0311289 | |
| n | 1 | 4 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 |
| d^n | 0.15 | 0.000506 | 0 | 0 | 0.5 | 9.31323E-10 | 0.5 | 9.31323E-10 | 0 | 0 | 0 | 0 |
| p | 0.941176471 | 0.949975 | 0.95 | 0.95 | 0.9 | 0.95 | 0.9 | 0.95 | 0.95 | 0.95 | 0.95 | 0.95 |
| std normal dist fn (Z) | 2.380425737 | 2.44754 | 2.447747 | 2.447747 | 2.145966 | 2.44774683 | 2.145966 | 2.44774683 | 2.4477468 | 2.4477468 | 2.4477468 | 2.4477468 |
| Z_p | 1.565053709 | 1.644966 | 1.645211 | 1.645211 | 1.281729 | 1.64521144 | 1.281729 | 1.64521144 | 1.6452114 | 1.6452114 | 1.6452114 | 1.6452114 |
| 1+(s/m)^2 | 1.412088253 | 1.412088 | 1.318932 | 1.318932 | 1.041244 | 1.04124372 | 1.175647 | 1.175647078 | 1.0144033 | 1.0144033 | 1.0579194 | 1.0579194 |
| (sigma_d)^2 | 0.345069639 | 0.34507 | 0.276822 | 0.276822 | 0.040416 | 0.040415883 | 0.161819 | 0.1618187 | 0.0143006 | 0.0143006 | 0.0563041 | 0.0563041 |
| mu_d | -6.98337693 | -6.983377 | 2.349222 | 2.349222 | -5.179633 | -5.179633309 | -5.064416 | -5.064415977 | 5.1858066 | 5.1858066 | 2.7902462 | 2.7902462 |
| (sigma_dn)^2 | 0.345069639 | 0.152489 | 0.276822 | 0.010575 | 0.040416 | 0.035447173 | 0.161819 | 0.044058165 | 0.0143006 | 0.00048 | 0.0563041 | 0.0019288 |
| mu_dn | -6.98337693 | -7.049099 | 2.349222 | 2.482345 | -5.179633 | -5.870296134 | -5.064416 | -5.698682889 | 5.1858066 | 5.1927169 | 2.7902462 | 2.8174339 |
| P_95 exponent | -6.06402324 | -6.406742 | 3.214832 | 2.65153 | -4.921958 | -5.560545272 | -4.548819 | -5.353352402 | 5.382549 | 5.2287614 | 3.18063 | 2.8896881 |
| P_95 (PEQ) | 0.002325028 | 0.00165 | 24.8991 | 14.17571 | 0.007285 | 0.003846678 | 0.01058 | 0.00473226 | 217.57618 | 186.56159 | 24.061907 | 17.987699 |
| | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average |

NOTES: For purposes of this summary, ^ represents an exponent or superscript while _ represents a subscript.
Variables are defined in Part 12, Rule 1225 (3) (a).

| Nickel | | Selenium | | Zinc | | Acrylonitrile # | | Chloroform # | | Azobenzene # | | Pentachlorophenol # | |
|------------------|------------------|------------------|------------------|-------------------|-------------------|-----------------|---------|--------------|------------|--------------|---------|---------------------|---------|
| 4 | | 4 | | 4 | | 4 | | 4 | | 4 | | 4 | |
| 3 | | 2 | | 4 | | 0 | | 1 | | 0 | | 0 | |
| 1 | | 2 | | 0 | | 4 | | 3 | | 4 | | 4 | |
| 0.25 | | 0.5 | | 0 | | 1 | | 0.75 | | 1 | | 1 | |
| 6.2666667 | | 2 | | 10.075 | | #DIV/0! | | 1.9 | | #DIV/0! | | #DIV/0! | |
| 0.7023769 | | 0.8485281 | | 4.56608877 | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | |
| 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 |
| 0.25 | 8.674E-19 | 0.5 | 9.313E-10 | 0 | 0 | 1 | 1 | 0.75 | 0.00017858 | 1 | 1 | 1 | 1 |
| 0.9333333 | 0.95 | 0.9 | 0.95 | 0.95 | 0.95 | #DIV/0! | #DIV/0! | 0.8 | 0.94999107 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 2.3272517 | 2.4477468 | 2.145966 | 2.4477468 | 2.44774683 | 2.44774683 | #DIV/0! | #DIV/0! | 1.79412258 | 2.44767387 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 1.5013852 | 1.6452114 | 1.2817288 | 1.6452114 | 1.64521144 | 1.64521144 | #DIV/0! | #DIV/0! | 0.84145672 | 1.64512482 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 1.0125622 | 1.0125622 | 1.18 | 1.18 | 1.20539913 | 1.20539913 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 0.012484 | 0.012484 | 0.1655144 | 0.1655144 | 0.18681074 | 0.18681074 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 1.8290026 | 1.8290026 | 0.61039 | 0.61039 | 2.21665174 | 2.21665174 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 0.012484 | 0.0116019 | 0.1655144 | 0.0443358 | 0.18681074 | 0.00682331 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 1.8290026 | 1.5417616 | 0.61039 | -0.022168 | 2.21665174 | 2.30664545 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 1.9967551 | 1.7189706 | 1.1318416 | 0.324249 | 2.92773857 | 2.44254535 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| 7.3651179 | 5.5787824 | 3.1013628 | 1.3829916 | 18.6853272 | 11.5022809 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| Max | Average | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average |

| Phenanthrene | | Cyanide, free | | Fluoranthene | | #N/A | | #N/A | | #N/A | | #N/A | |
|--------------|---------|---------------|------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 4 | | 4 | | 4 | | 0 | | 0 | | 0 | | 0 | |
| 0 | | 3 | | 0 | | 0 | | 0 | | 0 | | 0 | |
| 4 | | 1 | | 4 | | 0 | | 0 | | 0 | | 0 | |
| 1 | | 0.25 | | 1 | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | |
| #DIV/0! | | 7.06666667 | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | |
| #DIV/0! | | 4.27707065 | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | | #DIV/0! | |
| 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 | 1 | 30 |
| 1 | 1 | 0.25 | 8.6736E-19 | 1 | 1 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 0.93333333 | 0.95 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 2.32725168 | 2.44774683 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 1.50138519 | 1.64521144 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 1.36632253 | 1.36632253 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 0.31212285 | 0.31212285 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 1.79932747 | 1.79932747 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 0.31212285 | 0.02702366 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 1.79932747 | 1.65419499 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 2.63812068 | 1.92464925 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| #DIV/0! | #DIV/0! | 13.9868931 | 6.85274462 | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! | #DIV/0! |
| Max | Average | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average | Max | Average |

REASONABLE POTENTIAL ANALYSIS: WET

Facility: Ludington WWTP
 Outfall: 2

| Qe | Qr | RWC | PEL | | PEQ* | |
|-------------|----|------|-----------------|-----------------|-----------------|-----------------|
| | | | TU _C | TU _A | TU _C | TU _A |
| 6.965944272 | 65 | 9.68 | 10.331111 | 1 | 1.87 | 0.00 |

* PEQ (enter data for most sensitive species only):

Chronic

Total n = 38 Quant n = 19 CV = 0.3
 TU_C effluent = 1.7 MF = 1.1 PEQ TU_C = 1.87

Acute

Total n = 38 Quant n = 0 CV = 0.6
 TU_A effluent = 0 MF = 1.1 PEQ TU_A = 0.00

Decision (WET limits/conditions):

| WQBEL | | Species | TI/RE | Monitoring | |
|-------------|-----------|---------|-------|------------|-----------|
| Monthly Avg | Daily Max | | | Short term | Long term |

Basis of decision:

No Acute WET RP for either test species. No Chronic WET RP

Based on Chronic results for *C. dubia*, *C. dubia* is the more sensitive species. RP was evaluated using the *C. dubia* results. These results indicate no RP to exceed Chronic WET. Recommend Chronic and Acute WET testing for FHM in Additional Monitoring section. 4 tests over 5 years. Recommend quarterly monitoring for Chronic and Acute WET for *C. dubia* due to persistent low level toxicity. Remove limit from draft permit.

WET Data Summary

Species 1: fathead minnow

| Lab | Test Date | TU | | Reference |
|-----|------------|-------|---------|------------------|
| | | Acute | Chronic | |
| ERM | 9/10/2020 | 0 | 0 | |
| ERM | 8/4/2020 | 0 | 0 | |
| ERM | 7/14/2020 | 0 | 0 | |
| ERM | 6/2/2020 | 0 | 0 | |
| ERM | 5/12/2020 | 0 | 0 | |
| ERM | 4/14/2020 | 0 | 0 | |
| ERM | 3/17/2020 | 0 | 0 | |
| ERM | 2/18/2020 | 0 | 0 | |
| ERM | 1/15/2020 | 0 | 0 | |
| ERM | 12/10/2019 | 0 | 0 | |
| ERM | 11/12/2019 | 0 | 0 | |
| ERM | 10/3/2019 | 0 | 0 | |
| ERM | 9/5/2019 | 0 | 0 | |
| ERM | 8/13/2019 | 0 | 0 | |
| ERM | 7/16/2019 | 0 | 0 | |
| ERM | 6/11/2019 | 0 | 0 | |
| ERM | 5/21/2019 | 0 | 0 | Modified 10/4/00 |

| | | | |
|-----|------------|---|-----|
| ERM | 4/2/2019 | 0 | 0 |
| ERM | 3/1/2019 | 0 | 0 |
| ERM | 2/19/2019 | 0 | 0 |
| ERM | 1/8/2019 | 0 | 0 |
| ERM | 12/11/2018 | 0 | 0 |
| ERM | 11/6/2018 | 0 | 0 |
| ERM | 10/10/2018 | 0 | 0 |
| ERM | 9/11/2018 | 0 | 0 |
| ERM | 8/14/2018 | 0 | 1.7 |
| ERM | 7/26/2018 | 0 | 0 |

Species 2: C dubia

| Lab | Test Date | TU | | Reference | Coefficient of Variation and Multiplying Factor Calculation | |
|-----|------------|-------|---------|-----------|---|------------------------|
| | | Acute | Chronic | | Test Date | TUc values for CV Calc |
| ERM | 9/10/2020 | 0 | 1.7 | | 9/10/2020 | 1.7 |
| ERM | 8/4/2020 | 0 | 1.1 | | 8/4/2020 | 1.1 |
| ERM | 7/14/2020 | 0 | 1.7 | | 7/14/2020 | 1.7 |
| ERM | 6/2/2020 | 0 | 0 | | 6/2/2020 | 1 |
| ERM | 5/12/2020 | 0 | 0 | | 5/12/2020 | 1 |
| ERM | 4/14/2020 | 0 | 0 | | 4/14/2020 | 1 |
| ERM | 3/17/2020 | 0 | 0 | | 3/17/2020 | 1 |
| ERM | 2/18/2020 | 0 | 1.7 | | 2/18/2020 | 1.7 |
| ERM | 1/15/2020 | 0 | 1.7 | | 1/15/2020 | 1.7 |
| ERM | 12/10/2019 | 0 | 1.7 | | 12/10/2019 | 1.7 |
| ERM | 11/12/2019 | 0 | 0 | | 11/12/2019 | 1 |
| ERM | 10/3/2019 | 0 | 0 | | 10/3/2019 | 1 |
| ERM | 9/5/2019 | 0 | 1.7 | | 9/5/2019 | 1.7 |
| ERM | 8/13/2019 | 0 | 1.7 | | 8/13/2019 | 1.7 |
| ERM | 7/16/2019 | 0 | 1.7 | | 7/16/2019 | 1.7 |
| ERM | 6/11/2019 | 0 | 0 | | 6/11/2019 | 1 |
| ERM | 5/21/2019 | 0 | 0 | | 5/21/2019 | 1 |
| ERM | 4/2/2019 | 0 | 0 | | 4/2/2019 | 1 |
| ERM | 3/1/2019 | 0 | 1.7 | | 3/1/2019 | 1.7 |
| ERM | 2/19/2019 | 0 | 1.1 | | 2/19/2019 | 1.1 |
| ERM | 1/8/2019 | 0 | 1.7 | | 1/8/2019 | 1.7 |
| ERM | 12/11/2018 | 0 | 0 | | 12/11/2018 | 1 |
| ERM | 11/6/2018 | 0 | 1.7 | | 11/6/2018 | 1.7 |
| ERM | 10/10/2018 | 0 | 1.7 | | 10/10/2018 | 1.7 |
| ERM | 9/11/2018 | 0 | 1.7 | | 9/11/2018 | 1.7 |
| ERM | 8/14/2018 | 0 | 1.1 | | 8/14/2018 | 1.1 |
| ERM | 7/26/2018 | 0 | 0 | | 7/26/2018 | 1 |
| ERM | 4/10/2018 | 0 | 0 | | 4/10/2018 | 1 |
| ERM | 1/23/2018 | 0 | 0 | | 1/23/2018 | 1 |
| ERM | 10/17/2017 | 0 | 1.1 | | 10/17/2017 | 1.1 |
| ERM | 7/11/2017 | 0 | 1.1 | | 7/11/2017 | 1.1 |
| ERM | 4/11/2017 | 0 | 0 | | 4/11/2017 | 1 |
| ERM | 1/24/2017 | 0 | 0 | | 1/24/2017 | 1 |
| ERM | 10/11/2016 | 0 | 0 | | 10/11/2016 | 1 |
| ERM | 7/14/2016 | 0 | 1.7 | | 7/14/2016 | 1.7 |
| ERM | 4/19/2016 | 0 | 0 | | 4/19/2016 | 1 |
| ERM | 1/19/2016 | 0 | 0 | | 1/19/2016 | 1 |
| ERM | 12/1/2015 | 0 | 0 | | 12/1/2015 | 1 |

Standard Deviation 0.33361889

Mean 1.27105263

Effluent-Specific CV 0.26247449

=0.3